ENVE 302 Term Project 1 (2011-2012)

In the scope of this project, each group will prepare the detailed design of the following units for the given influent characteristics.

The project report will be submitted on **01.05.2012**. Presentation hours will be announced later.

The design will include the detailed process calculations for the following units:

Conventional activated sludge system including only carbon removal

For each process unit, the following scaled Autocad drawings will be prepared:

- 1. Plan view
- 2. Cross-section
- 3. Longitudinal section

Each drawing will include a legend. The legend will consist of at least the followings:

- -Drawing name
- -Group name
- -Scale of drawing

On each drawing, the dimensions will be shown in mm.

The report will include the following sections:

- Cover Page
- Content page
- Executive summary
- Brief description of process
- Detailed process calculations
- Selection of necessary equipment (e.g, WAS pumps, RAS pumps, blowers, diffusers etc.)
- Reference list (All references listed here will be referred in the report)
- Appendixes: Source code of all computer programs to be used, Drawings (should be inserted in a clear file)

Layout of the proposed plant

Summary table given on page 3

Influent Characteristics:

Average daily flowrate : 15 000 m³/day
Peak daily flowrate : 20000 m³/day

BOD : 300 mg/L
COD : 600 mg/L
TSS : 400 mg/L
TKN : 70 mg/L
NH₄-N : 45mg/L
Org-N : 25 mg/L
TP : 10 mg/L

Alkalinity : 170 mg/L as CaCO₃

Wastewater Temperature

Min. Temp. : 14 °C Max. Temp. : 24 °C

Ambient Temperature

Min. Temp. : 12°C Max. Temp. : 29°C

Altitude of the treatment plant site: 150 m

EFFLUENT PARAMETERS

 $\begin{array}{lll} BOD & \leq 25 \text{ mg/L} \\ TSS & \leq 35 \text{ mg/L} \\ NH_4\text{-N} & < 0.5 \text{ mg/L} \\ Organic N & < 2.0 \text{ mg/L} \\ NO_3\text{-N} & \leq 7.5 \text{ mg/L} \\ Total N & \leq 10 \text{ mg/L} \\ Total P & \leq 3 \text{ mg/L} \end{array}$

The below table should be filled by each group

DADAMETERS	
PARAMETERS	
Q design (m3/d)	
Design temperature (0C)	
DO conc. in the tank, mg/L	
effluent C conc. (g/m3)	
effluent N conc. (g/m3)	
Minimum required sludge age,day	
Design sludge age, day P x, biomass (kg/day)	
\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	
Px, VSS (kg/day)	
Px, SS (kg/day)	
MLSS, mg/L	
MLVSS, mg/L	
Total volume, m3	
number of tanks	
volume of each tank(m3)	
tank dimensions	
width (m)	
length (m)	
depth (m)	
SVI (ml/g)	
X _R (mg/L)	
R	
% solids in RAS	
RAS PUMPS	
Number	
Capacity (m3/d)	
Capacity (mora)	
WAS Pumps	
% solids in WAS	
70 SOIIUS III WAS	
Niversia	
Number	
Capacity (m3/d)	
Oxygen calculations	
Temperetaure, 0C	
AOTR (kg/hr)	
SOTR (kg/hr)	
number of blowers	
capacity of each blower (m3/hr)	
total blower capacity (m3/hr)	
Tatal gameless of Pff	
Total number of diffusers	
Number of diffusers in each tank	