

ENVE 302
Term Project 2 (2011-2012)

In the scope of this project, each group will prepare the detailed design of the following units for the given influent characteristics.

The project report will be submitted on **01.05.2012**. Presentation hours will be announced later.

The design will include the detailed process calculations for the following units:

Conventional activated sludge system including carbon removal and nitrification

For each process unit, the following scaled Autocad drawings will be prepared:

1. Plan view
2. Cross-section
3. Longitudinal section

Each drawing will include a legend. The legend will consist of at least the followings:

- Drawing name
- Group name
- Scale of drawing

On each drawing, the dimensions will be shown in mm.

The report will include the following sections:

- Cover Page
- Content page
- Executive summary
- Brief description of process
- Detailed process calculations
- Selection of necessary equipment (e.g, WAS pumps, RAS pumps, blowers, diffusers etc.)
- Reference list (All references listed here will be referred in the report)
- Appendixes: Source code of all computer programs to be used, Drawings (should be inserted in a clear file)

Layout of the proposed plant

Summary table given on page 3

Influent Characteristics :

Average daily flowrate : 15 000 m³/day
Peak daily flowrate : 20000 m³/day

BOD : 300 mg/L
COD : 600 mg/L
TSS : 400 mg/L
TKN : 70 mg/L
NH₄-N : 45mg/L
Org-N : 25 mg/L
TP : 10 mg/L
Alkalinity : 170 mg/L as CaCO₃

Wastewater Temperature

Min. Temp. : 14 °C
Max. Temp. : 24 °C

Ambient Temperature

Min. Temp. : 12°C
Max. Temp. : 29°C

Altitude of the treatment plant site: 150 m

EFFLUENT PARAMETERS

BOD ≤ 25 mg/L
TSS ≤ 35 mg/L
NH₄-N < 0.5 mg/L
Organic N < 2.0 mg/L
NO₃-N ≤ 7.5 mg/L
Total N ≤ 10 mg/L
Total P ≤ 3 mg/L

The below table should be filled by each group

PARAMETERS	
Q design (m ³ /d)	
Design temperature (°C)	
DO conc. in the tank, mg/L	
effluent C conc. (g/m ³)	
effluent N conc. (g/m ³)	
Minimum required sludge age, day	
Design sludge age, day	
P _x , biomass (kg/day)	
P _x , VSS (kg/day)	
P _x , SS (kg/day)	
MLSS, mg/L	
MLVSS, mg/L	
Total volume, m ³	
number of tanks	
volume of each tank (m ³)	
tank dimensions	
width (m)	
length (m)	
depth (m)	
SVI (ml/g)	
X _R (mg/L)	
R	
% solids in RAS	
RAS PUMPS	
Number	
Capacity (m ³ /d)	
WAS Pumps	
% solids in WAS	
Number	
Capacity (m ³ /d)	
Oxygen calculations	
Temperature, °C	
AOTR (kg/hr)	
SOTR (kg/hr)	
number of blowers	
capacity of each blower (m ³ /hr)	
total blower capacity (m ³ /hr)	
Total number of diffusers	
Number of diffusers in each tank	